

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay
Jim Doyle, Governor
Richard J. Leinenkugel, Secretary

October 9, 2009

BRADLEY CORPORATION THOMAS R EBERHARDY W142 N9101 FOUNTAIN BLVD PO BOX 309 MENONMONEE FALLS WI 53052-0309

Re: Description: HEALTH CARE PLUMBING APPLIANCE

Manufacturer: BRADLEY CORPORATION

Product Name: PATIENT CARE UNIT

Model Number(s): LC500, LC700, LC700, LC750, LC800 AND LC2000

Product File No: 20090350

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2015.

This approval is contingent upon compliance with the following stipulation(s):

- When this product has a built-in bedpan washer that has a shut off valve on the discharge, a vacuum breaker meeting ASSE Standard 1056 must be installed in the water supply serving only the bedpan washer. The vacuum breaker must be installed with its critical level at least 12" above the highest point downstream where backpressure would be created.
- When this product has a built-in bedpan washer that does not have a shut off valve on the discharge, a vacuum breaker meeting ASSE Standard 1001 must be installed in the water supply serving only the bedpan washer. The vacuum breaker must be installed with its critical level at least 6" above the highest point downstream where backpressure would be created.

This approval supersedes the approval issued on March 31, 2005 under product file number 20050108.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050108.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson Plumbing Product Reviewer Phone: 608-266-6742

Fax: 608-267-9566

E-mail: jerry.thompson@wi.gov

SBD-10564-E (N.10/97) File Ref: 09035001.DOC